

UL INTERNATIONAL (UK) LTD Wonersh House, Building C, The Guildway, Old Portsmouth Road, Guildford. GU3 1LR. United Kingdom.





designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, www.eota.eu)

## European Technical Assessment

ETA 18/0922 of 12/12/2018

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: UL International (UK) Ltd

Trade name of the construction product Knauf FPG - fire protection graphite

Product family to which the construction product belongs

Fire Stopping and Sealing Product:

Penetration Seals

**Manufacturer** Knauf Sp. Z o.o.

ul. Światowa 25 02-229 Warsaw

Poland

Manufacturing plant(s) A/003

This European Technical Assessment

contains

22 pages including 1 Annex which forms an integral part of this assessment.

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of

EAD 350454-00-1104, September 2017.

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

### **Table of Contents**

I.	SPE	ECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT	. 3
1		Technical description of the product	. 3
2		Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): EAD 350454-00-1104	. 3
3		Performance of the product and references to the methods used for its assessment	. 5
4		ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE	. 6
5		Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD	. 6
6		Issued on:	. 7
ANN	EX A	– Resistance to Fire Classification – Knauf FPG - fire protection graphite	. 8
FI	exibl	le or rigid wall constructions with wall thickness of minimum 100 mm	. 8
	A.1	1 Penetration seals, in drywalls* and concrete/masonry walls	. 8
	A.1	2 Penetration seals with no backing material, in drywalls and concrete/masonry walls	10
Α	.2	Rigid walls constructions with wall thickness of minimum 150 mm	13
	A.2	Penetration seals for pipes, in concrete/masonry walls	13
	A.2	Penetration seals for cables, in concrete/masonry walls	14
	A.2	Penetration seals for pipes, in concrete/masonry walls	15
Α	.3	Rigid floor constructions with floor thickness of minimum 150 mm	16
	A.3	Penetration seals, surface mounted in concrete floors	16
	A.3	Penetration seals, surface mounted in concrete floors	18
	A.3	Penetration seals, surfaces mounted in concrete floors	19
	A.3	Penetration seals, surface mounted in concrete floors	21

### I. SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT

#### 1 Technical description of the product

- Knauf FPG fire protection graphite is a sealant and pipe closure device used to form penetration seals
  where insulated metallic pipes, combustible pipes, combustible cable conduits and cables penetrate walls
  and floors.
- 2) The Knauf FPG fire protection graphite is supplied in liquid form contained within 310 & 380 ml cartridges and 600 ml foil packs. The sealant is gunned into the aperture in the separating element and around the service or services, to a specified depth utilising mineral fibre insulation backing material.
- 3) The applicant has submitted a written declaration that the product and/or constituents of the product contains no substances which have been classified as dangerous according to Directive 67/548/EEC and Regulation (EC) No. 1272/2008 and listed in the 'indicative list on dangerous substances' of the EGDS taking into account the installation conditions of the construction product and the release scenarios resulting from there.

In addition to the specific clauses relating to dangerous substances contained in this European Technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

4) The use catagory of Knauf FPG - fire protection graphite in relation to BWR 3 (Hygiene, health and environment) is IA1, S/W3

### 2 Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): EAD 350454-00-1104

Detailed information and data is given in Annex A.

The intended use of system Knauf FPG - fire protection graphite is to reinstate the fire resistance performance of flexible wall and rigid wall and floor constructions, where they are penetrated by services.

1) The specific elements of construction that the system Knauf FPG - fire protection graphite may be used to provide a penetration seal in, are as follows:

Flexible walls: The wall must have a minimum thickness of 100 mm and comprise steel studs

lined on both faces with minimum 2 layers of 12.5 mm thick boards. The walls must also incorporate a full fill core insulation of Stonewool (35kg/m3 density).

Rigid walls: The wall must have a minimum thickness of 100 mm and comprise concrete,

aerated concrete or masonry, with a minimum density of 650 kg/m3.

Rigid floors: The floor must have a minimum thickness of 150 mm and comprise aerated

concrete or concrete with a minimum density of 650 kg/m3.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.

2) The system Knauf FPG - fire protection graphite may be used to provide a penetration seal with specific supporting constructions and substrates (for details see Annex A).

- The provisions made in this European Technical Assessment are based on an assumed working life of the Knauf FPG fire protection graphite of 30 years, provided that the conditions laid down in the manufacturers data sheet and instructions for the packaging/transport/storage/installation/ use/repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.
- 4) Type  $Z_2$ : intended for use at internal conditions with humidity classes other than  $Z_1$ , excluding temperatures below 0°C.

## 3 Performance of the product and references to the methods used for its assessment

Product-type: Sealant/Pipe	closure	Intended use: Penetration Seal					
Basic requirement for construction work	. Rasic Ren		Performance				
BWR 2 Safety in case of fire							
EN 13501-1	Reaction to fire		Class F (not tested)				
EN 13501-2	Resistance to fire		Annex A				
BWR 3 Hygiene, health and environment							
EN 1026	EN 1026 Air permeability						
EAD 350454-00-1104, Annex C	Water permeability		No performance determined				
Declaration of manufacturer & EN 16516	Content, emission and/or release of dangerous substances		Use categories: IA1, S/W3  Declaration of manufacturer				
EOTA TR 001:2003	Mechanical resista	ance and stability	No performance determined				
EOTA TR 001:2003 Resistan		pact/movement	No performance determined				
EOTA TR 001:2003	Adhe	sion	No performance determined				
EAD 350454-00-1104, Clause 2.2.9	Durability		Z <sub>2</sub>				
BWR 5 Protection against noise							
EN 10140-1,2,4,5/ EN ISO 717-1	Airborne sound insulation*		53 (0;-1) dB				
BWR 6 Energy economy and heat retention							
EN 12664, EN 12667, EN 12939, EN ISO 8990, EN ISO 6946, EN ISO 14683, EN ISO 10211, EN ISO 10456	Thermal p	roperties	No performance determined				
EN ISO 12572, EN 12086, EN ISO 10456 Water vapour		permeability	No performance determined				

<sup>\*</sup> At 25 mm depth

# 4 ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE

According to the decision 1999/454/EC – Commission Decision of date 22nd June 1999 on the procedure for attesting the conformity of construction products pursuant to Article 20(2) of Council Directive 89/106/EEC as regards fire stopping, fire sealing and fire protective products, published in the Official Journal of the European Union (OJEU) L178/52 of 14/07/1999, see http://eur-lex.europa.eu/JOIndex.do) of the European Commission<sup>1</sup>, as amended, the system(s) of assessment and verification of constancy of performance (see Annex V to Regulation (EU) No 305/2011) given in the following table(s) applies (apply).

Product(s)	Intended use(s)	Level(s) or class(es)	System(s)
Fire stopping and Fire Sealing Products	For fire compartmentation and/or fire protection or fire performance	Any	1

## 5 Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD

Tasks of the manufacturer:

Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall ensure that the product is in conformity with this European Technical Assessment.

The manufacturer may only use initial / raw / constituent materials stated in the technical documentation of this European Technical Assessment.

The factory production control shall be in accordance with the Control Plan of 1<sup>st</sup> July 2014 relating to the European Technical Assessment ETA 18/0922 issued on 12/12/18 which is part of the technical documentation of this European Technical Assessment. The "Control Plan" is laid down in the context of the factory production control system operated by the manufacturer and deposited at UL International (UK) Ltd.

The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan.

\_

<sup>&</sup>lt;sup>1</sup> Official Journal of the European Communities L178/52 of 14/7/1999

### Other tasks of the manufacturer

### Additional information

The manufacturer shall provide a technical data sheet and an installation instruction with the following minimum information:

- (a) Technical data sheet:
  - Field of application:
  - Building elements for which the penetration seal is suitable, type and properties of the building elements like minimum thickness, density, and - in case of lightweight constructions – the construction requirements.
  - Limits in size, minimum thickness etc. of the penetration seal
  - Construction of the penetration seal including the necessary components and additional products (e.g. backfilling material) with clear indication whether they are generic or specific.
- (b) Installation instruction:
  - Steps to be followed
  - Procedure in case of retrofitting
  - Stipulations on maintenance, repair and replacement

### 6 Issued on:

12th December 2018

Report by:

D. Yates Project Engineer

**Building and Life Safety Technologies** 

For and on behalf of UL International (UK) Ltd.

Reviewed by:

C. Johnson Staff Engineer

**Building and Life Safety Technologies**